

AUTHORIZED GAS TESTER (AGT)

Course Material



EMERGENCY PROCEDURES

Be Aware

Emergency Exits

Fire Alarm





INTRODUCTION

LET'S GET TO KNOW EACH OTHER...

Would you kindly tell us your:

Name

Job

Experience

Experience of CSE





COURSE RULES

Mobile Phone usage

(please be courteous)

Breaks


Prayers

Participation

No Smoking

Toilets







ADNOC UNIFIED HSE POLICY

business practices.

ADNOC GROUP

The ADNOC Group is committed to:

Impacts to our businesses.

any unsafe work.

In our employees.

to 100% HSE.

safety and the integrity of our assets.

and the welfare of our workforce.

HEALTH, SAFETY & ENVIRONMENT (HSE) POLICY

The Abu Dhabl National Oil Company (ADNOC) and its Group of Companies (together the ADNOC Group) are committed to the

highest standards of HSE excellence by protecting our people,

communities and the environment; ensuring effective security

Pursuing the goal of no harm to people and the community.

3 Implementing cost-effective measures to improve energy efficiency and promote the use of renewable energy.

4 Ensuring compliance with all applicable laws, regulations, policies and procedures relating to HSE.

management and business continuity measures in place.

6 Managing risks through effective controls and minimizing

Focusing on incident prevention by managing process

8 Promoting sustainability, corporate social responsibility

Embedding a 100% HSE culture that empowers

employees and contractors to Intervene and stop

10 Developing and sustaining HSE critical competencies

and employees accountable for HSE performance.

13 Engaging business partners who are also committed

The ADNOC Group will implement this Policy through a comprehensive HSE management system.

11 Holding all levels of management, supervisors,

12 Setting targets for HSE performance and

continuous improvement.

Having world-class emergency response, crisis

commitment to address the global challenge of climate change.

2 Protecting the environment and supporting the UAE's

and business continuity measures; and following sustainable



مجموعة أدنوك سياسة المحة والسلامة والبيئة

تلتزم شركة بترول أبوظيى الوطنية (أحنوك) ومجموعة شركاتها (مجموعة أدنوك) بتحقيق أعلى المعايير الصالمية للتميز فم الأداء في مجالت الصحة والسلامة والبيئة وخلك من خلىل حماية الموظفين والمجتمعات والبيئة، كما تتزم باتخاذ تجابير فعالة تضمن الثمن واستمرارية الأعمال واتباع ممارسات مستدامة لمزاولة أعمالها ونشاطاتها.

تلتزم مجموعة أدنوك بما يلي:

- 1 السعى لتحقيق هدف عدم إلحاق الثذن بالثفراد والمجتمع.
- 2 حماية البيئة ودعم التزام دولة الإمارات العربية المتحدة بالتصدي لظاهرة التغير المناخص التي تواجه العالم.
- 3 تطبيق تدابير فعالة من حيث التظفة لتحسين كفاءة الطاقة وتشجيع التوسع فى استخدام الطاقة المتجددة.
- 4 الامتثال للقوانين واللوائح والسياسات والبجراءات المطبقة ذات الصلة بالصحة والسلامة والبيئة.
- 5 تبني خطة ذات معايير عالمية للاستجابة لحالت الطوارئ وإدارة الأزمات واستمرارية الأعمال.
- 6 إدارة ظفة المخاطر من خلال منهجية تعتمد على تطبيق تدابير فعالة تحد من تأثيرات تلك المخاطر على العمليات.
 - 7 التركيز على منع وقوع الحواحث من خلال إدارة إجراءات السلامة وحماية الأصول.
 - 8 تعزيز الاستدامة والمسؤولية المجتمعية ورعاية كوادرنا.
 - 9 ترسيخ ثقافة الصحة والسلامة والبيئة (100%) لتمكين كلفة الموظفين والمقاولين المتعاملين معنا من التحخل لمنع أي أعمال تشكل خطراً على السلامة.
 - 10 التطوير والمحافظة على القدرات الأساسية في مجال الصحة والسلامة والبيئة لدى موظفينا.
- 11 عدم التهاون في محاسبة المسؤولين والمشرفين والموظفين في كافة المستويات على أدائهم في مجالات الصحة والسلامة والبيئة.
- 12 وضع أهداف للثداء في مجالت الصحة والسلامة والبيئة والعمل على تطويره بصورة مستمرة.
 - 13 التعاون مع شركاء التعمال الذين التزموا بميثاق 100% صحة وسلامة وبيئة.

ستقوم مجموعة أدنوك بتطبيق هذه السياسة من خلىل نظام شامل. لإدارة الصحة والسلامة والبيئة.

د. سلطان أحمد الجابر, الرئيس التنفيذي لمجموعة أدنوك Dr. Sultan Ahmed Al Jaber, ADNOC Group Chief Executive Officer

April 2018

100%

Embedding a 100% HSE culture that empowers employees and contractors to intervene and stop any unsafe work



- ADNOC Confined Space Standard (HSE-OS-ST08)
- ADNOC Permit to Work Standard (HSE-OS-ST02)
- ADNOC Management of Hydrogen Sulfide (H2S Standard) (HSE-OS-ST21)



HEALTH SAFETY ENVIRONMENT MANAGEMENT SYSTEM CONFINED SPACE STANDARD

HEALTH SAFETY ENVIRONMENT MANAGEMENT SYSTEM PERMIT TO WORK STANDARD (WMS)



KEY CONTENTS

- Life Saving Rules
- Introduction, Case Study and Gas Test History
- ✤ Hazardous Atmosphere
- Oxygen Deficiency/Enrichment
- Flammable & Explosive Gases
- Toxic Gases
- Gas Test Practices Record Form
- Terminology and Definitions
- Relative Density & Gas Dispersion
- Gas Testing locations and Practices
- Authorised Gas Test (AGT) & Area Authority (AA) Responsibilities Within Safe System of Work
- Gas Monitoring (Fixed/Portable/Personal)
- Bump Test and Calibration
- **BW** Gas Alert Micro 5
- ✤ Assessment











WORK AUTHORIZATION Work with a valid permit when required











LINE OF FIRE

out of the line of fire

Keep yourself and others

SAFE MECHANICAL

Plan lifting operations

and control the area

TOXIC GAS

Follow the rules for working

in toxic gas environments

LIFTING

BYPASSING SAFETY CONTROLS Obtain authorization before £ 18. overriding or disabling safety controls





HOT WORK







This is THE ADNOC WAY



LIFE SAVING RULES (LSRS)










AUTHORIZED GAS TESTING (AGT)



LIFE SAVING RULES (LSRS)







WORK AUTHORIZATION



PERMIT

WORK WITH A VALID WORK PERMIT WHEN REQUIRED

- I have confirmed if a permit is required
- I am authorized to perform the work
- a I understand the permit
- I have confirmed that hazards are controlled and it is safe to start
- I stop and reassess if conditions change

Section 7.9 in the Standard shall be referred for Work Authorization



CONFINED SPACE



OBTAIN AUTHORIZATION BEFORE ENTERING A CONFINED SPACE

- I confirm energy sources are isolated
- I confirm the atmosphere has been tested and monitored
- I check and use my breathing apparatus when required
- I confirm there is an attendant standing by
- I confirm rescue plan is in place
- I obtain authorization to enter



Section 7.2 in the Standard shall be referred for the Confined Space



TOXIC GAS



FOLLOW THE RULES FOR WORKING IN TOXIC GAS ENVIRONMENTS

- I follow safety precautions before entering toxic gas environments
- I inspect my gas detector and respiratory protection equipment before use
- I stay alert and prepare myself for emergency evacuation
- I take action whenever toxic gas protection control barriers are compromised



LIFE SAVING RULE VIOLATION: TOXIC GAS

Case#1				
Title of Incident	Exposure to Toxic Gas			
Date	03 rd February 2009 at 07:35 hrs.			
Location	Corrosion Coupon Pit (Near Sha-1 Station) on Shah-Asab transfer line (Mile-58)			
Severity	Three Fatalities and One Serious Injury			
Life Saving Rules (LSRs) Requirements Violated	 Crew member entered inside the pit without obtaining valid Permit to Work (PTW) "Work Authorization: I am authorized to Perform the Work" Crew entered without confirming that atmosphere has been tested and monitored (Confined Space entry requirement) Safety Precautions were not followed before entering toxic gas environments (Toxic Gas requirement) 			







EXPOSURE TO TOXIC GAS IN SHAH FIELD



What happened:

On 3rd February 2009 at 07:35 hrs, Four employees in Shah Field were exposed to H2S while draining a transfer line inside a corrosion coupon pit. The pit was approximately 12 feet deep (confined space). Three fatalities and one serious injury occurred from this incident. The injured person was air evacuated to hospital where he was treated, recovered and subsequently discharged from the hospital.

Why it happened:

- Violation of Procedure (PTW & Confined Space Entry Certificate).
- Breathing apparatus was not used and personal H2S detector was switched
- off. Exposure to lethal concentration of H2S in confined space.
- Inadequate identification of job hazards.
- Inadequate reinforcement of procedures.
- Inadequate Identification of Training Needs.
- Inadequate reinforcement of critical safe behavior.
- Inadequate Guards & Warning Systems.

Lessons Learnt:

AUTHORIZED GAS TESTING (AGT)

- Provide personal H2S detectors to all personnel including laborers/helpers working in H2S exposed areas.
- Ensure all helper/laborers are fully trained for performing their assigned tasks.
- Establish Access Control on all confined spaces with effective markings, signs & tagging; and locking, where applicable.
- Ensure PTW is issued based on task risk assessment (TRA) and the high risk TRA has been endorsed by a safety professional (Safety & Loss Prevention Engineer (SLPE) as minimum).
- Confined space entries cannot be made unless a SLPE has signed off the Confined Space Entry Certificate and he has reviewed the emergency plan
- Include practical element (step test) and confined space entry in H2S/BA training course and for all
 operation/ production and HSE staff.
- Empower laborers/workers to STOP unsafe activities and initiate contractual arrangements to protect/encourage individuals exercising ADCO STOP Policy.





HOT WORK



CONTROL FLAMMABLES AND IGNITION SOURCES

- I identify and control ignition sources
- Before starting any hot work:
- I confirm flammable material has been removed or isolated
- I obtain authorization
- Before starting hot work in a hazardous area, I confirm:
 - A gas test has been completed
 - Gas will be monitored continually





LIFE SAVING RULE VIOLATION "HOT WORK"



Case#1		
Title of Incident	Rumaitha CPP Fire Incident	
Date	20 th August 2016 at 14:21 hrs.	
Location	Rumaitha CPP Heating Medium Area	
Severity	Major damage to the Plant equipment, piping and structure	
Life Saving Rules (LSRs) Requirements Violated	Flammable sources were not controlled	





RUMAITHA CPP FIRE INCIDENT



What Happened :

On 20th August 2016, oily water leak was observed from a Glass Reinforced Epoxy (GRE) pipe joint connected to the oil inlet of the 2nd stage desalter in Rumaitha CPP. While the GRE contractor was collecting information in preparation for repair, they heard a noise and observed that the GRE line ruptured from the joint. Subsequently, hot crude oil (600C) splashed over the GRE team members (3 people), which resulted in first degree burns to one of them. On hearing the sound they evacuated the site immediately. The released hydrocarbon near the pipe rack caught fire spontaneously. Fire and Gas Detectors in the heating medium area activated the Emergency shutdown (ESD-1), resulting in automatic total plant shutdown. Desalter' deluge system activated automatically. Deluge system for the stabilization column was activated manually. Plant was depressurized manually by activating blowdown system (ESD-0). Entire Plant was evacuated and emergency teams were mobilized.



Why It Happened:

- No provision of NRV on the GRE line that is connected to the oil inlet line to prevent reverse flow.
- Poor workmanship has resulted in wrong installation of backing ring on the GRE stub joint.
- Operations manually increased the flow across the leaking GRE flange. This has caused vibration on the GRE line resulting in the failure of flange.
- The decision to shut down was delayed by underestimating the potential consequences of the leak.

Lessons Learnt:

- Water leaks from the GRE line in hydrocarbon process facilities should not be considered as routine and the potential consequences of such leaks shall be assessed and control measures shall be initiated immediately.
- Critical operations decisions shall be based on risk assessment and timely action to be taken.
- Design and constructability of GRE lines in hydrocarbon handling and processing facilities shall be reviewed considering the increased number of leaks due to GRE line failures.
- Review the existing operations pre-fire plans to cover all potential scenarios and conduct more frequent exercises accordingly to ensure effective preparedness and response.
- Headcount system in all ADCO locations shall be reviewed and strengthened.





INTRODUCTION

ABU DHABI NATIONAL OIL COMPANY



WHY GAS TEST?

Most times people seem to forget that the atmosphere is what's keeping us alive and if not sufficiently monitored can lead to catastrophic injuries, damaged assets, environmental pollution and fatalities. There have been abundant fatalities recorded from failures to detect gas and minimize its harmful effects.

Organizations would need to apply learned lessons to prevent gas releases by putting in place the right measures to detect gases and control them if a leak occurs to avoid any catastrophic event.

Gas testing is a very sensitive operation and should be conducted with extreme care, due to its importance of testing and checking the atmosphere's Air quality where our colleagues will enter and perform a task in areas where there is a potential health and flammable/explosive hazard.



Area



LOSS OF CONTAINMENT RESULTING IN FATAL VEHICLE FIRE



Incident Description

Root Causes

- Inadequate Identification of Worksite/Job Hazards (Risks associated with external corrosion of flowlines & inadequate corrosion inspection, flowline replacement and location of flowlines were not adequately assessed)
- **Inadequate Job Placement** (Staff were not sufficiently familiar with maintenance of the ESD system and long time taken to resolve the ESD problem)



Lesson Learned

- 1. Revise flowline design specifications; and integrity assurance practices to consider flowline leaks as an "abnormal" occurrence.
- 2. Amend procedures & instructions such that night operation is considered as an abnormal and higher risk activity.
- 3. Review design philosophies and over pressure protection from the well head through RDSs all to the CDS in view of changing reservoir conditions, flowline aging and recent enhanced design practice
- 4. Review emergency response procedure to consider an ESD on the plant as an 'emergency' event.
- 5. Review specifications for coveralls with respect to fire resistance for both ADCO and contractor staff.





After the normalization of Central Degassing Station (CDS) following an instrumentation failure induced Emergency Shut Down (EDS), operation teams were dispatched to the field to open closed-in wells. A fire was observed at Bu-407 flow line, approx. 200 m away from the well head and the well was isolated at the wellhead. A field services team (driver and four crew members) proceeded to RDS-3 to de-spade the Bu-407 drain line. Approx. 300 m from RDS3 on the main access (Gatch) track, there had leaked oil from Bu-570 flowline on the track. Upon crossing the oil pool, the oil and/or crude oil vapors ignited and the vehicle caught fire.

Outcome: The vehicle fires resulted in four fatalities. One crew member escaped unhurt.

BUH 07.05.2011



AUTHORISED GAS TESTER (AGT)



A Gas Tester authorized in writing by Asset Owner following satisfactory completion of formal training and assessment of competence to carry out atmospheric tests and interpret the results obtained in terms of flammability or toxicity.

Only Authorized Gas Tester (AGT) with valid certificates shall conduct the tests.

Personnel involved in atmospheric testing shall undergo a training and formal certification in the use of atmospheric testing equipment.

Only those who completed the training and declared competent shall be included in the list of Authorized Gas Tester.







AUTHORISED GAS TESTER (AGT)



Every Gas tester must have clear Idea on What he is Testing, Why he is Testing & How to Test.

AGT must understand

- Risk from gases & vapors
- Their potential to cause Fire & explosion
- Effects of the on Human body
- How gases reacts
- Where to test the atmosphere to locate them
- Risk involved during testing







AUTHORISED GAS TESTER (AGT)



NEVER RUSH & PUT YOUR OWN LIFE IN RISK

- Plan the test
- Asses the Risk
- Consider what must be done to reduce the Risk as ALARP



Remember

The life of your colleagues depends on your readings.



NORMAL AIR COMPOSITION



NAME	SYMBOL	PERCENT BY VOLUME
Nitrogen	N2	78.084%
Oxygen	O2	20.9476%
Argon	Ar	0.934%
Carbon Dioxide	CO2	0.0314%
Neon	Ne	0.001818%
Methane	CH4	0.0002%
Helium	He	0.000524%
Krypton	Kr	0.000114%
Hydrogen	H2	0.00005%
Xenon	Xe	0.000087%

The table gives the sea-level composition of air (in percent by volume at the temperature of 15° C and the pressure of 101325 Pa).



OPERATIONS BEING TESTED FOR FLAMMABLE AND TOXIC GASES



Types of Operations being tested includes but NOT limited to:

- 1. Entry into a confined space
- 2. Hot work to be carried out in hazardous area
- 3. Vehicle entry to hazardous area
- 4. Breaking containment

5. Gas leak





GAS TESTING HISTORY



Canary in cage. Flame safety lamp Catalytic combustion sensor













HAZARDOUS ATMOSPHERE

ABU DHABI NATIONAL OIL COMPANY

EX-OX-TOX DANGER



Basically there are three categories of risk

- Risk of explosion by flammable gases
- Oxygen (Risk of asphyxiation by oxygen displacement)

Risk of increase of flammability by oxygen enrichment

• Risk of poisoning by toxic gases



Without auxiliary tools humans are not able to recognize these dangers early enough to initiate appropriate counter measures. With only some exceptions our nose has turned out to be an extremely unreliable warning instrument.

Even harmless gases such as argon, helium or nitrogen may become dangerous when the vitally important oxygen is displaced by a sudden release. Danger of suffocation!

100%

OXYGEN DEFICIENCY-ENRICHMENT



The hazard in the atmosphere can vary from being toxic or oxygen deficient to being flammable or explosive. It is imperative to fully understand the difference between the hazards, what type of hazard can be present and the most likely situations to appear:

Oxygen Deficiency:

Risk of Suffocation, Oxygen can be consumed or displaced by another gas

Oxygen Enrichment

Risk of fire, High levels of O2 increase the flammability of material and gases – at levels such as 24%, items such as clothing can spontaneously combust!







OXYGEN DEFICIENCY-ENRICHMENT



Oxygen deficiency may be caused by the following:

1. Oxygen displacement by other gases and vapors, such as inert gases or by evaporating liquids.

2. Oxygen consumption through rusting metals (oxidation), combustion, respiratory consumption by workers, or organic decay of aqueous molasses or drying of paints

3. Oxygen absorption or adsorption, where molecules adhere to the surface of a solid body such as damp carbon.

OXYGEN - BETWEEN 19.5% - 23.5% IS ACCEPTABLE IN ADNOC STANDARDS AN OXYGEN READING OF OVER 23.5% IS OXYGEN ENRICHED AN OXYGEN READING OF UNDER 19.5% IS OXYGEN DEFICIENT



OXYGEN DEFICIENCY



CONCENTRATION LEVEL	EFFECTS	
19.5%	Minimum Permissible Level	
15-19%	Decreased Ability To Work Strenuously (hard)	
12-14%	Increase In Pulse & Respiration	
10-12%	Lips Blue. Further Respiration Increase	
8-10%	Fainting, Mental Failure, Nausea & Vomiting	
6-8%	8 Minutes -100% Fatal. 6 Minutes -50% Fatal, 4-5 Minutes - Recovery With Treatment	
4-6%	Coma In 40 Seconds. Convulsions, Respiration Ceases-Death	

Enhanced oxygen concentrations (e.g. more than 25 Vol%) cannot be sensed by people, but have severe consequences in respect to the flammability characteristics of materials, and may even cause auto-ignition. This is the reason why explosion protection measures are only related to the atmospheric oxygen concentration

FLAMABLE / EXPLOSIVE



Flammable/explosive atmospheres, which may be caused by the following:

- 1. Vaporization of flammable liquids
- 2. By-products of chemical reactions
- 3. Flammable gases
- 4. Elevated airborne concentrations of combustible dust
- 5. Gases from decomposition



Flammable & Explosive Gases - e.g. Methane, Butane, Propane - Risk of fire and/or explosion

Remember: It's not just gas that holds a potential threat – dust can also be explosive! Examples of explosive dusts include polystyrene, cornstarch and iron.



FLAMABLE / EXPLOSIVE


Sources of Ignition


- Welding/ Cutting Torch
- Friction
- Grinding Sparks
- Hot Surfaces
- Static Charges
- Smoking
- Open Flame
- Using Mobile Phones
- Electrical Short or Arcing
- Pyrophoric Materials













TOXIC GASES



Toxic Gases

Risk of Poisoning

e.g. Carbon Monoxide, Hydrogen Sulfide, SO2

(It should be noted that there is a large group of gases which are both combustible and toxic, so that even detectors of toxic gases sometimes have to carry hazardous area approval).

The main reason for treating flammable and toxic gases separately is that the hazards and regulations involved and the types of sensor required are different.





COMMON GASES



Common toxic gases in the oil and gas industry include:

- Hydrogen Sulfide (H2S)
- Carbon Monoxide (CO)

- Oxygen Depletion (O2)
- Sulphur Dioxide (SO2)
- Benzene (C6H6)

- Carbon Dioxide (CO2)
- Ammonia (NH3)




Some of these poisonous gases may be easily identifiable by an individual upon exposure while others are not. For instance, hydrogen sulfide has an odor similar to that of a rotten egg, whereas carbon monoxide is a colorless, odorless, and tasteless toxic gas. By the time a person may or may not realize they are in the presence of a toxic gas they may have already been exposed at a life-threatening level.

HYDROGEN SULPHIDE (H2S)



Extremely toxic, ranking second to Hydrogen Cyanide (HCN) and five (5) to six (6) times more toxic than Carbon Monoxide (CO)

- Colourless
- Smells like rotten eggs in low concentrations
- Heavier than air SC=1.189
- Readily disperses by the wind
- Highly corrosive to certain materials
- Soluble in both Water & Hydrocarbons
- Ignition temperature 260 deg. C
- Burns with a blue flame and produces SO₂









The oil $\$ gas industry is usually concerned with H_2S The presence of H2S in hydrocarbon is usually termed as sour crude.

H2S is a high toxic gas, if you detect its presence in concentrations exceeding Permissible Exposure Limit you must Evacuate the area, alert others and call for a gas test.






GAS PARTS PER MILLION (PPM)



- If a million parts of air by volume contains one part of H2S it is 1PPM H2S in air
 - 1PPM = 0.0001%
 - · 10 PPM = 0.001%
 - 100 PPM = 0.01%
 - 1000 PPM = 0.1%
 - 10,000 PPM = 1%




ADNOC Classification: Internal



GAS PARTS PER MILLION (PPM)



- Change from PPM to volumetric percentage % and vice versa
 - 700 PPM = ?%
 - 9000 PPM = 0.9%
 - ? PPM = 4.3%
- ? PPM = 27%
- 5% of LEL of H2S is safe or unsafe?





THE TOXICITY OF H2S GAS WAS RESPONSIBLE FOR



BUHASA, 11TH MAY 2002 Three men died in the back of a truck at GASCO's

BuHasa plant.

ADGAS - Das Island, 22nd November 2008 One fatality

> ADCO - Shah, 3rd February 2009 Three fatalities due to H2S release



CARBON MONOXIDE



Carbon Monoxide (CO) is colorless, odorless and a by-product of incomplete combustion.

CO is flammable and has an Lower Explosive Limit (LEL) of 12.5%.

CO is very toxic it can be absorbed 200-300 times faster than oxygen by the hemoglobin

CONCENTRATION LEVEL	EFFECTS
50 PPM	Permissible Exposure Level (8 Hours)
200 PPM	Slight Headache & Discomfort(3 Hours)
400 PPM	Headache & Discomfort (2 Hours)
1000-2000PPM	Confusion, Headache, Nausea (1/2 Hour)
2000-2500 PPM	Unconsciousness (1/2 Hour)
4000 PPM	Fatal less than 1 hour







NH3 is colourless gas with a suffocating odour. NH3 is flammable with an LEL

level of 15%. However it is difficult to burn. NH3 is extremely toxic.

Harmful Effects of Ammonia (NH3)

РРМ	EFFECTS
0-25	Minor irritation of eyes and respiratory tract
25	Permissible exposure level TWA
35	Short Term Exposure Level (STEL)
50-100	Swelling of eye lids, vomiting, irritation of the throat
100-600	Very dangerous, potential deadly from prolonged exposure



ALARM LEVELS



TYPE OF ALARM	02	LEL	H2S
Low Alarm	19.5%	5%	10 PPM
High Alarm	23.5%	10%	15 PPM





GAS TEST PRACTICES

ABU DHABI NATIONAL OIL COMPANY

100% HSE

ATMOSPHERIC TESTING



Atmospheric tests, where required by the permit, shall be carried out as appropriate to cover all activities within the designated area.

The atmospheric testing shall be carried out as close as possible to commencement of work.

The responsibility to determine the atmospheric testing requirements (location of tests, frequency, gases to be tested and other requirements as specified on the Atmospheric Test Record Form) shall lie with the Area Authority





DOCUMENTATION



ATMOSPHERIC TEST RECORD FORM .

The 'Atmospheric Test Record' form is located on the reverse side of the permit form.

For continuation of test records, a new form can be attached to the permit pack.

Personnel involved in atmospheric testing shall undergo a training and formal certification in the use of atmospheric testing equipment.

Personnel must be aware of the existing standards for the relevant airborne contaminants and be able to interpret the results of the test.

Validity - Not applicable / Re-validation - Not applicable

Form No																				
		OSPHERIC TE						TAILS												
		Section 2 shall	l be fille	1 by Arei	a Aut	hority	y (AA)			-					T					
Location	/ Area to b	e Tested								Atta	chment (fany.)								
Permit R	of 1		T	ype		+	Refe	rence	#	Cert	ificate Re	6 1			עד	pe		Reference	e#	
Permit R	ef 2.				_					Cert	ificate Re	12			+					
Permit R Permit R											fficate Re Ifficate Re				F					
		DSPHERIC TE	ST REG	UIREM	ENT	5				Car	Incate He	14			i.					
Test Fre	quency									ed Gases	to be Te	sted				Ot	ers (Specify)		
	start work authorizatio	n			Yes	H	No No		ygen droca	arbon			Yes		No No	┝┥╢ _{───}				
Each wo	rk period				Yes		No	H2	s				Yes		No	□				
Continue	ist Frequen Duis Gais Mo	nitoring Regula	ed		-			CO SO					Yes Yes		No No	┝┥╢				
(if contin	uous, docu	ment results p	rlor to w	ork	Yee		No		mon	la			Yes		No	H				
	N 3 - ATM	OSPHERIC TE		ULTS																
Material	Oxygen (% Vol.)	Hydrocarbon (%LEL)	H2S (ppm)	CO (ppm)		SO2 (ppr		Ammo (ppm)	nla	Others (1)	Others (2)	Test	ing		A.I.	-	Employee	Classification	Data	Time
Safe Limits	> 19.5% < 23.5%	< 5% LEL	<5 ppm	< 25 p	pm	<2 p	-	< 25 p	pm	Limita	Limita	Equ	pmer	It ID	Nar	ne (AGT)	No.	Signature	Date	Time
		-															-			
									_								<u> </u>			
	<u> </u>			<u> </u>	-		\rightarrow		-			-			-					
	<u> </u>		-		\neg				-			-			-					
			<u> </u>				-													
	L								_											
	<u> </u>				\neg		_		-			-			-					
	<u> </u>		-	<u> </u>	+		\rightarrow		\dashv			-			\vdash				<u> </u>	
			<u> </u>												\vdash		<u> </u>			
	<u> </u>			<u> </u>					_			-					-			
Test Results	<u> </u>		-	-	-		-		-			-			-					-
	<u> </u>		-	<u> </u>	\neg		\rightarrow		+			-			-		-		<u> </u>	-
	<u> </u>			<u> </u>					_			-								-
	<u> </u>		+	<u> </u>	-				-		<u> </u>	-			-		+			-
	<u> </u>		-	<u> </u>			\rightarrow					-			-					-
	<u> </u>			<u> </u>			_					-					-		<u> </u>	
	<u> </u>			<u> </u>	_		_		_			-			-				<u> </u>	-
	<u> </u>		-		-		-		-			-			-		-			-
	L		+		-							-			-		1	1		-



ATMOSPHERIC TEST RECORD FORM



Atmospheric Tests shall always be conducted by an Authorized Gas Tester (AGT) and results recorded on an Atmospheric Test Record Form.

Atmospheric test shall be considered as per the nature of the work basis the controls identified in the permit/certificates.

AGT must Communicate abnormal atmospheric test information to the AA.

Ľ	53				R	EC	0	RD	FC	DRM								1040	ĉ
Form No																			
		SPHERIC T	EST REC	ORD FO	DRM E	NTRY D	DET	AILS											
		Section 2 sh									_								
Location	/ Area to b	Tector		-		-			4112	chment (1	(unv)								_
COOLINA		- ICOLO		-			100	ence #		ion in the fire ge	ang.		_	Turne			Reference		_
Permit R	ef 1.			ype	-	H		ence#	Cer	tificate Re	<u>n</u>		_	Туре			Reference	e#	-
Permit R							_			tificate Re			_						-
Permit R Permit R										tificate Re									_
		SPHERIC T	EST REG	UIREM	ENTS				Cer	tificate Re	14								
Test Fre			LOTINE	onnem.				Require	d Gase	s to be Te	sted			_	Oth	ers (Specify)			
Prior to a	start work				Yes	No	T	Oxygen				Yes		No					1
	authorizatio rk period	n			Yes	No No	+	Hydroca H2S	arbon			Yes Yes		NO NO					
	st Frequenc	ay lis			PC0	11.40	-	CO			-	Yes		No					_
Continue	ous Gas Mo	nitoring Reg.	uired	auto.	Mar 1	- N-	_	SO2				Yes		No					
start at e	uous, docu Iach shift)	ment résults	hinor ro M	And And	Yes (No	L	Ammon	la			Yes [No 🗌					
SECTIO		SPHERIC T																	
Material	Oxygen (% Vol.)	Hydrocarbo (%LEL)	n H2S (ppm)	CO (ppm)		02 (pm)		(mmonia (ppm)	Others (1)	Others (2)	Test					Employee			1
Safe	> 19.5%	<5% LEL	<5	<25 p	-	2 ppm	+	25 ppm	Limita	Limite	Equi	ing prment	D	Name ((AGT)	Employee No.	Signature	Date	
Limits	* 23.076		ppm		-		÷			-	-							-	4
			-		-		+			-	-		_						+
	<u> </u>		-	<u> </u>	-		+											<u> </u>	+
					-		+												+
			-				t			<u> </u>									1
	<u> </u>				-		$^{+}$												1
							T												1
																			Τ
			_				+												4
	<u> </u>				_		+			<u> </u>									4
	<u> </u>		_		-		+												4
	<u> </u>						+			-	-							 	+
	<u> </u>		+				+			-	-							+	+
Test	<u> </u>		+	<u> </u>	-		+			<u> </u>								<u> </u>	+
Results			-		-		+						_					<u> </u>	+
			+				$^{+}$			1									1
							+												1
																			I
							T						_						1
			_															-	
	<u> </u>		_				+											-	4
	L				_		+				_							<u> </u>	4
	<u> </u>			<u> </u>	-		+				-			<u> </u>				<u> </u>	4
	<u> </u>		-		-		+			-	-								+
							+				-								+
	<u> </u>		+		-		+			-	-							<u> </u>	+
			+		-		+			-	-							+	+
	<u> </u>			<u> </u>	-		+			+	-							<u> </u>	+

Records must be kept-retained for minimum 12 months



SECTION 1 – ATMOSPHERIC TEST RECORD FORM ENTRY DETAILS



10	0%
Ш	SE

Earm No

ATMOSPHERIC TEST RECORD FORM



Form No											
SECTION 1 - ATMOSPHERIC TEST RECORD FORM ENTRY DETAILS											
Note: Section 1 and Section 2 shall be filled by Area Authority (AA)											
Location / Area to be Tested	ocation / Area to be Tested Attachment (if any.)										
	Туре	Reference #		Туре	Reference #						
Permit Ref 1.			Certificate Ref 1								
Permit Ref 2.			Certificate Ref 2								
Permit Ref 3.			Certificate Ref 3								
Permit Ref 4.			Certificate Ref 4								

The Area Authority (AA) shall enter the following details on the Atmospheric Test Certificate:

- 1. Location / Area to be atmospheric tested;
- 2. Permit Work Title as stated on permit for which atmospheric test is required;
- 3. Details of associated certificates i.e. Confined Space Entry, Isolations, etc.



SECTION 2 – ATMOSPHERIC TEST RECORD FORM ENTRY DETAILS



SECTION 2 - ATMOSPHERIC TEST REQUIREMENTS											
Test Frequency					Required Gases to be Tested					Others (Specify)	
Prior to start work	Yes		No		Oxygen	Yes		No			
Prior to authorization	Yes		No		Hydrocarbon	Yes		No			
Each work period	Yes		No		H2S	Yes		No			
If yes, Test Frequency is					СО	Yes		No			
Continuous Gas Monitoring Required			_		SO2	Yes		No			
(if continuous, document results prior to work start at each shift)	Yes		No		Ammonia	Yes		No			

(AA) shall also determine the frequency of the atmospheric tests to be conducted. The Risk Assessment associated with the permit/ Confined Space Entry/ Vehicle Entry shall be used as a basis for determining atmospheric testing requirements / frequency. The following instructions entered by the AA on the Atmospheric Test Record Form:

- 1. Whether an atmospheric test is required prior to commencement of work;
- 2. Whether an atmospheric test is required at beginning of each work period. If yes, then frequency (in hours) shall be specified;
- 3. Whether continuous atmospheric testing is required; and
- 4. Required gases to be tested.



SECTION 3 – ATMOSPHERIC TEST RESULT



Section 3 – Atmospheric Test Record Form Entry Details:

The AGT shall record the details of atmospheric test on the Atmospheric Test Record Form.

The Forms shall be retained at the worksite at all times.

Material	Oxygen (% Vol.)	Hydrocarbon (%LEL)	H2S (ppm)	CO (ppm)	SO2 (ppm)	Ammonia (ppm)	Others (1)	Others (2)	Testing	Nama (AOT)	Employee	0:t	Data	Time
Safe Limits	> 19.5% < 23.5%	< 5% LEL	< 5 ppm	< 25 ppm	< 2 ppm	< 25 ppm	Limits	Limits	Testing Equipment ID	Name (AGT)	Employee No.	Signature	Date	Time
Toot														
Test Results														-



DOCUMENTATION



										SECTI	ON 4 - F	ERMIT /	APPROV	AL.										
100%										I have a	reviewed	the perm	nit and th	e attachr									he work to	ALARP. I confirm
IHSE.			WOR						-		y of Appr		to autho Day		and work o	an com	mence when all th		ed controls and If less than ma				r daus	
								ADNO				pproval A			Com	Danv		oyee ID	Position	A BAR AND A BAR A	Date & T		Sign	
Permit No:			Previous Permit No:		200	ork Order No:					prosect right	pp.ora ri	an of the	1000	- Com	pany	- Crip	0,0010	r carbon		001001		- Sign	
SECTION 1: PERMIT REC	UEST		remode Permit No.			one onder not				SECTI	ON 5 - P			IZATION										
1. (a) Nature of Work (tic		opriate)		_				_		I have	reviewed	the perm	nit and th	e attachr	ments and	l confirm	n that the describ	d contro	is are adequate	to reduce th	e risks as	sociated with t	he work to	ALARP. I confirm
				Œ		S [nted as per the rec r timing conflict wi				ans will be	e communicate	d to the Jo	b Performer (JP)
Hot Work		nit Blasting	Explosives	Heat Ge	53F	Grinding	Inter	nal Comb	untion	Zero Er	neigy				6/11	required		ot requir	ad A	uthorization	Delegatio	an (/If	delegated	to Pl for RFO)
(Naked Flame)		in baseng	Explosives	Heat Ge	Nerabon	Grinding	Inter	Engines	asoon		v of perm		Days								-		-	
1. (b) Work Title														Date	н	rs	Valid Till**:			Date Stamp for	finst issue o	sdmum limit of con nly (Specify time s	ot if required	ender deye
						anned Start Date	_										energy demonst		be done by del	egated pers	onnel with	h the assistanc	e of other l	solating
4 (-11 11 1 m - 1					Р	anned Finish Date Process /	Non - Proce				Ibes. Fur Area Aut		authoriza	tion requ	irements: Com		done by Pl as dele	geted.	Position		Date & T			
1. (c) Location / Equipme Location / Area	sint				Area	Restricted	Unrestricted			Name	(Area Au	montys			Com	pany	Emp	oyee ID	Position		Date & I	ime Sigr		
					H2S Zone	R A	Y 🗌 G		NC	SECTI	ON 6 - V	VORKSI	TE ISSU	E & SUSE	PENSION									
Equipment ID / Teg No.	_				HAC Zone*	0 0 1 0	2		NC 🗌								rk period	_			6b. Pe	ermit Susper	slon	
Equipment Description					Dust Zone*	20 21	22		NC 🗌		uthority (lesuer (PI)	Job Pe	rformer (JP)			rformer(JP)	_	Owner Rep
1. (d) Description of Wor	'k				* HAC: Hazardou	s Area ClasselFoation													the worksite as safe d have witnessed Ze		1			
it full is a second state of the																I have ch	tecked workalite	des appli	cable). I will commu	nicate the				
										Loanfirm	that all We	of with Cont	trois are at	l in place at	nd		apecified on the femonatrated Zaro	to work	permit controls are party members incl	uting the JSA/		amined the workal from the tit has	finotau	spended by JP* I
1. (e) Work Equipment D	etails			Job Per	lormer (JP) Det	alls:				effective	s as per the	nequineme ng comflict v	nis of the p alth any off	ennit. Then	relano amit or		as applicable) & d on-site emergency	via TDT	esament or SHCS r and remain at workp	lace for the		tin safe condition. uspand the Permit	and con	amined the workalte firm that it has been
Tools to be used					/ Department					activity.						instructi	ione to JP: I confirm e la safe to commence	ecope a	of work. Lundersta nd precautions to b	e taken. Lagree	and conf	from that my person been removed.	al Instrument	afe conditional hereby d the permit.
				Name (s)												work.		deeprib	by the controls and id in the permit. Leg	nee to not				
Sources of Ignition					io. of workers													provides	to work unit cleans	nce has been vr (PI).				
Hezerdous Meteriais Involv	ed			Contract		Planned	No	/Emerge		Date	Shift/ Exten-			Name &	Initiale	Time	Name & Initials	Time	Name & Initials	JP Lock	Time	Name & Initials	Time	Name & Initials
1. (f) Work Permit Reque	et hy Per	forming Authorit	v (PA)	WORK P10	nning (IWAP)	Planned	Dreak-in	/ Emerge	ney	Cane	sion	From	To				in the difficult		in the other of the other	No.		rearrie a monta		Harris & Hildes
I confirm that the details in	the permi	t and associated at	tachments provide a clear of	lescription of	he work to be pe	rformed including too	ols, materials	and any				Not App	plicable f	or first is	9449			<u> </u>			<u> </u>			
			for the work activity is comp																	_			_	
Name (Performing Authorit	5d	Company	Employee ID	Position	D	ete & Time	Sign			<u> </u>										_				
SECTION 2 - WORKSITE	CONTRO	I S AND SUPPOR	TING DOCUMENTS							<u> </u>	+	+	<u> </u>					+			<u> </u>			
Certificates:	(if regd)		Attachments:	(if regd.)	No#	Other Details					+	-						-			-		+	
1. Electrical isolation			1. Method Statement			JSA (Ref. No.)					1	-											-	
2. P/1/Misolation			2. Lifting Plan			Remote Field Open	ation (RFO)	Yes	No 🗆															
3. Temp. Defeat			3. P&ID			Planned SIMOPS		Yes	No 🗆															
4. Atmospheric Test			4. Rescue Plan			PA Worksite Preser of yes, specify deta		? Yes 🗆	No 🗆															
5. Confined Space Entry			5. Journey Management P	ion 🗆		Special Precaution														_			_	
6. Ionizing Radiation 7. Vehicle Entry		+	6. Hezard & Control Sheet 7. Job Safety Analysis (Inv			+				\vdash		-								-	-		-	
8. Excervation		1	8. Associated Permits	<u>≕ </u>		+				<u> </u>	-	-						-		-	-			
9. Diving		1	Other:		1	†				SECT	ON 7 - P	RMIT	CLOSUR	E										
10. Road Closure			Other:			1					ermit Ret													
11.Essement			Other:								ite clear				Yes	No	Work Comp	lete	Yes No					
			A) * This section applies if							House	keeping	is satisfe	ctory		Yes	No	Permit Can	celled	Yes No					
	the permi		ttachments is clear, valid an									in sefe co			Yes	No	Bemerka							
Name		Company	Employee ID	Position	D	ete & Time	Sign					dy to retu		vice	Yes	No				omplete or p		cancelled, pleas		reason
SECTION 3 - PERMIT EN	DORSEM	ENT								Name	Perform	ing Autho	ority)		Company	/	Employ	ee ID	Position		Date & T	ime	Sign	
			ed to mitigate interface / co	ncurrent activi	ties agree that th	e work described may	y be carried o	out during	the	7.0b)P	ermit Ci	losure					I							
proposed period.											te clear			Yes	No] Equi	pment left in safe	ondition	Yes	No				
Name		Company	Employee ID	Position	P	ete-& Time	Sign			House	keeping	is satisfe	ctory	Yes	No	Wori	Continuing unde	Permit						
										Name					Company	у	Emplo	/ee ID	Position		Date & T	lime	Sign	
										(Permit														
										(Area A	uthority3													
Original copy (JP); Tet copy (AA or	PCF or point	offissuance); 2nd copy	(Control Room if different from PC	P)															Fat	n No: FM-OSS	102-03 I W	ension No: 01 I Eff	ective Date: A	April 2019 I Page 1 of 1





- An atmospheric test shall always be conducted prior to Confined Space Entry.
- Initial testing should be done from outside the confined space by inserting a sample probe and/or portable gas detection device at appropriately selected access holes, nozzles and openings.
- Because contaminants can settle at different levels, each part of the confined space should be tested – side to side and top to bottom. For example, some gases (such as H2S) are heavier than air and in unventilated areas will settle to the bottom of the space, while other gases (such as CH4) are lighter than air and will collect at the top of the space



AUTHORIZED GAS TESTING (AGT)





- Testing should be carried out on a sufficient number of points to accurately reflect areas of the space that is likely to be accessed.
- Re-testing and continuous monitoring of the air may be necessary if the risk assessment indicates that conditions may change due to the work being done or due to disturbance of hazardous material in the confined space.
- The conditions should also be continuously monitored, for example, when forced ventilation is being used or when the work activity itself could give rise to changes in the atmosphere.







- Continuous gas monitoring shall be maintained for any Confined Space entry activity.
- Man entry into vessels is allowed only when Continuous monitoring of LEL, O2 and SO2 inside the vessel.

Consideration for Inert Gas CSE

- Continuous oxygen monitoring shall be ensured and the Authorized Entrant shall be alerted to evacuate the Confined Space if the oxygen level inside is exceeded.
- An audio-visual oxygen alarm set at 5% is recommended which should be carried in a way that Authorized Entrant is able to see or feel or hear the alarm while wearing the breathing apparatus.







- The frequency of subsequent testing shall be stipulated on the Atmospheric Test Record Form based on the Risk Assessment.
- A confined space located within H2S classified area shall be monitored continuously.
- While work is being carried out in a confined space, it is required to ensure that the concentration any flammable gas, vapor or mist in the atmosphere of the space is less than 5% of its LEL, so far as is reasonably practicable.







If it is not reasonably practicable, and the concentration of any flammable gas, vapor or mist in the atmosphere of the confined space:

- Is equal to or greater than 5% but less than 10% of its LEL—the person must ensure that any worker is immediately removed from the space unless a suitably calibrated, continuous monitoring flammable gas detector is used in the space;
- Or is equal to or greater than 10% of its LEL—the person must ensure that any worker is immediately removed from the space.



• Where a flammable atmosphere may exist in a confined space and there is a risk of fire and explosion, all ignition sources in the vicinity must be eliminated.





Some abbreviations are used constantly in the process of gas testing.

The abbreviations and chemical properties of the gases and vapours commonly found in the industry must be understood by all concerned.







AUTHORIZED GAS TESTING (AGT)



TERMINOLOGY AND DEFINITIONS



Threshold Limit Value (TLV)

Is a level to which a worker can be exposed per shift in the worktime without adverse effects. TLV is a reserved term of the American Conference of Governmental Industrial Hygienists (ACGIH).

Threshold Limit Value -Time-Weighted Average (TLV-TWA):

The concentration of a hazardous substance in the air averaged over an 8-hour workday and a 40-hour workweek to which it is believed that workers may be repeatedly exposed, day after day, for a working lifetime without adverse effects.

Threshold Limit Value -Short-term exposure (TLV STEL):

A 15-minute time weighted average exposure that should not be exceeded at any time during a workday, even if the overall 8-hour TLV-TWA is below the TLV-TWA. Workers should not be exposed more than four times per day to concentrations between TLV-TWA and TLV-STEL.





TERMINOLOGY AND DEFINITIONS



Immediately Dangerous to Life or Death (IDLH)

An atmospheric concentration of any toxic, corrosive, or asphyxiate substance that poses an immediate threat to life or would cause irreversible or delayed adverse health effects or would interfere with an individual's ability to escape from a dangerous atmosphere.



The IDLH for H2S is 100 ppm



TWA / STEL FOR H2S



Workplace monitoring limit (Personal H2S Detector) 10 ppm.

Occupational Health Use (Chronic effects)

Workplace Exposure Limit [8-hr TWA] 5 ppm Workplace Exposure Limit [15-min STEL] 10 ppm







RELATIVE DENSITY



With the exception of Gases such as, Methane, Carbon Monoxide and Hydrogen most flammable gases have a density greater than air.

This is important because it can result in a layering effect where a flammable mixture is present at one level and not at another.



THE HIGHER THE RELATIVE DENSITY THE HEAVIER THE SUBSTANCE e.g. (H2S) density =1.19 and (AIR) density = 1.0



RELATIVE DENSITY



Lighter than Ai	r	Heavier than Air	r	
Acetylene	0.9	Argon	1.38	Hethan
Ammonia	0.59	Arsine (AsH ₃)	2.69	(lighter than air)
СО	0.966	CO ₂	1.518	Carbon Monsuide
Helium (He)	0.138	SO ₂	2.264	(same as air)
H2	0.069	Propane	1.521	Bydrages Sallide (bassier than air)
CH ₄	0.553	Ozone (O3)	1.660	
N2	0.972	Oxygen (O ₂)	1.104	
		H ₂ S	1.19	From the Octaide, Top to Bottom




RELATIVE DENSITY



If you want to test H2S where you can find it?

CO2 CO H2S SO2 CH4 H2






GAS DISPERSION



Factors influencing gas dispersion:

Gravity / Air current Plumes / gas leak at high pressure Wind speed Heat Humidity



GAS TESTING LOCATIONS



Where you can find gases?

- Pits
- Sumps
- Manholes
- Flanges
- Valves gland/ stem
- Roof Seal of Floating Roof Tank
- Points, gages, etc...

- Pump Casing
- Drains
- Sewers
- Cellars
- Christmas tree
- well-head
- Casings
- Sludge
- Vents







GAS TESTING PRACTICES



The GAS TESTER is usually first on the scene. He must take precautions. Do not neglect your personal safety and therefore the safety of others who come after you whilst doing gas tests.

AGT

Must be aware of the gases that the instrument can detect.

Must also be aware of that the presence of other gases can adversely effect the readings.

When testing in an area it must be considered that gases may be stratified rather than uniformly mixed, spot checks must be carried out for precise readings.

Assessment must be made of the exact location, type of gas, the wind direction and the strength of the wind.



RESPONSIBILITY



THE CARRYING OUT OF GAS TESTS IS A JOB WHICH CARRIES A GREAT DEAL OF RESPONSIBILITY

Workmate lives may depend upon YOUR readings!

Gas Testing must be done with extreme care and understanding of the characteristics of the gases and vapours which could be present.

The course will not only look at how to carry out the tests but also will discuss interpretations of the readings and limitations of the instrument.





AGT - RESPONSIBILITIES



- Assess the work location and identify (in liaison with Area Authority) all atmospheric testing requirements for the safe execution of work.
- Verify that acceptable conditions exit to perform the proposed activity by performing atmospheric tests and documenting the information on the Atmospheric Test Record Form as required.
- Ensure testing equipment is fit-for-purpose, calibrated, and functional.
- Communicate abnormal atmospheric test information to the Area Authority.
- The AGT shall record the details of atmospheric test on the Atmospheric Test Record Form.

AGT - RESPONSIBILITIES



AGT shall be competent to:

- Demonstrate ability to operate atmospheric testing equipment and its care;
- Understand requirements of filling atmospheric test record forms;
- Demonstrate actions to be taken if gas detector alarms.



All efforts shall be made to conduct Atmospheric Test within 1 hour prior to the commencement of the work.

Job Performer (JP) and Authorized Gas Tester (AGT) shall not be the same person for the subject PTW

A person's senses should never be used to determine if the air in a confined space is safe. Many toxic or flammable gases and unsafe oxygen levels cannot be detected using one's senses

100%

AA - RESPONSIBILITIES



- Location / Area to be atmospheric tested
- Whether an atmospheric test is required prior to commencement of work;
- Whether an atmospheric test is required at beginning of each work period.

If yes, then frequency (in hours) shall be specified;

- Whether continuous atmospheric testing is required; and
- Required gases to be tested.





GAS MONITORING

ABU DHABI NATIONAL OIL COMPANY



TYPE OF DETECTORS



Fixed Detector: is permanently installed in a chosen location to provide continuous monitoring of plant and equipment. useful where there is the possibility of a leak into an enclosed or partially enclosed space where flammable gases could accumulate.

Portable Detector: usually refers to a small, handheld device that can be used for testing an atmosphere in a confined space before entry, for tracing leaks or to give an early warning of the presence of flammable gas or vapor when hot work is being carried out in a hazardous area.

Transportable Detector: not intended to be hand-carried but can be readily moved from one place to another. One of its main purposes is to monitor an area while a fixed gas detector is undergoing maintenance.



FIXED DETECTORS



STRENGTH	WEAKNESS
Continuous Detection	Accurate detection is limited to gas that diffuses into the sensing inlet – requiring strategic placement of detectors
Site wide Alarms	Demand constant power supply
Events can be recorded	Capital installation cost can be expensive depending on the amount of equipment required
Data can be logged	Requires regular service checks – just like a fire alarm system
Clear Unambiguous alarm	Needs strategic locations
Used indoor or outdoor	Limited area typically 5M radius
Zone classified	



100% HSE

PORTABLE DETECTORS



STRENGTH	WEAKNESS	
Easily to carry	Monitoring only when the unit is on.	
Multi gas detection	Needs charging	\cap
Presence of pump	User must be trained	Quickly switch from
Presence of probe	Need bump test	diffusion to integral pump option
Cab be used remotely	Costly if used as the only gas detection system for large areas.	Multiple charging
Transportable	Each Worker requires their own unit.	options available
Used for tracing leaks		

100% HSE

PERSONAL DETECTORS



STRENGTH	WEAKNESS
Easy to carry	Warning device only
Self powered	Individual protection only
Can be tracked centrally	The detector alarm/activated when the wearer is in hazardous contaminated area
Intrinsically safe	Operator must be trained
Light weight	Need daily self test Need bump test every 3 months
Cost effective	





BUMP TEST



- A short exposure of a detector to a test gas to an expected concentration that is greater than the alarm set points which demonstrates that the sensor and alarm are operational, without carrying out a calibration.
- Bump testing is the only way to ensure proper sensor and alarm functionality.
- The purpose of the bump test is to check for sensor and alarm functionality. However, it does not check for accuracy.
- It is important to note that accuracy is ensured through calibration, which is a completely different process than bump testing.
- The bump test for personal gas detectors shall be done once in a month or according to manufacturer's recommendation whichever comes earlier.
- However, for portable gas monitors used by Authorized Gas Tester shall be bump tested before every use.
- Records for the bump testing shall be maintained.
- Any gas monitor that fails to respond properly during a functional bump test shall be sent for troubleshooting or further maintenance as required.



CALIBRATION




The equipment used for monitoring the exposure levels of H2S shall be serviced and tested at intervals recommended by the manufacturer, and possibly more frequently under extreme humidity, temperature, dust or other adverse environmental operating conditions.

AUTHORIZED GAS TESTING (AGT)

Status calibration shall be checked before every use of portable gas monitors in accordance with the manufacturer's recommendation.

Records of device testing and maintenance shall be kept for verification and audit purposes.





CALIBRATION



Calibration is a quantitative test utilizing a known traceable concentration of test gas to demonstrate that the sensor(s) and alarms respond to the gas within manufacturer's acceptable limits. It is the adjustment of the baseline and sensitivity of the sensor/electronics circuit, that is, it is based on an exposure to a known gas in which the sensor/instrument is adjusted to that concentration.

Calibrations are required on a periodic basis. All sensors regardless of the operational principle, will drift over a period of time and require adjustments. Sensors may also experience drift after an over-exposure to the targeted gas, or after exposure to extreme environmental conditions, after a severe physical jolt, or if a Function Test produces a less than satisfactory result. It is important to observe the response times of the sensors, the stability of the sensor signal, and the recovery times of the sensors during this period.

The calibration interval for each of these sensors from the different makers of the instruments may be different.

The frequency of calibration shall be governed as per the manufacturer's recommendation as indicated in the instruction manual for the routine test and re-calibration interval.



RECOMMENDED BUMP TEST & CALIBRATION FOR THE GAS MONITORS & GAS DETECTORS




	Gas Detector/ Monitor	Personal H2S Monitors		Portable Multi-Gas Detectors	Area Monitor (Stand Alone) Gas Detectors	
	Brand	BW	Crowcon	BW	Crowcon	OLDHAM
	Model	Gas Alert Clip 2 Extreme	Crowcon Clip	Gas Alert Miro5	Detective	BM 25
AUTHORIZED GAS TESTING (AGT)	Bump Test Frequency	 At least every 90 days (3 Months) Bump test to be conducted by Assets HSE. Each Asset to arrange and ensure availability of bump test kit with the necessary training of use. Functional self-test to be performed by users prior to daily use. 		 Daily or prior to use. Bump test to be conducted by Assets HSE. 		
	Calibration Frequency	 Not required (dispose after 2 years operating life). Calibration is required if the monitor failed the bump test and to be conducted by Assets HSE. 		 Recommend every 3 months (quarterly) due to the work environment. Assets HSE to send the units to the GSD Mussafah Safety Work Shop on quarterly basis for calibration 		Mussafah Safety
82	Maintenance Tracking Process	51		tracked by using Safety	r Equipment Tracking S	ystem.



BW – GAS ALERT MICRO 5







BW – GAS ALERT MICRO 5



Instrument model differences		
GasAlertMicro 5		
Gases Detected H ₂ S, CO, O ₂ , SO ₂ , PH ₃ , NH ₃ , NO ₂ , HCN, Cl ₂ , ClO ₂ , O ₃ and combustibles (LEL)		
Sensors	Plug-in, electrochemical cell (toxic and oxygen); catalytic (LEL)	
Typical battery life ²		
AA Alkaline 20 hours		
Rechargeable 20 hours		


GasAlertMicro 5			
Industry or Application	Sources of 5 th Atmospheric Hazards		
Confined Space Entry	Various sources - industrial chemicals		
Wastewater Plants	Cl ₂ , NH ₃ , ClO ₂ from treatment		
Steel / Iron Production	NO ₂		
Pulp and Paper	Cl ₂ from bleaching		
Food and Beverage	NH3 from refrigerants, ice production PH3 from fumigation		
Construction	Confined space entry, trenching, and NO ₂ from diesel exhaust		

Sensor Specifications			
Gas	Measuring Range (ppm)		
H ₂ S	0-500		
C0	0-999		
TwinTox (H ₂ S)	0-500		
TwinTox (CO)	0-500		
0 ₂	0-30.0%		
S0 ₂	0-150		




BW – GAS ALERT MICRO 5





Item	Description	
1	Visual alarm bars (LED)	
2	Sensors	
3	Audible alarm	
4	Pushbuttons	
5	Liquid crystal display (LCD)	
6	Battery pack	
7	Alligator clip	

To replace a sensor or sensor filter, refer to Figure 8, Table 19, and the following procedures.





120	00	02
SO ₂	Cl ₂	CIO ₂
NH_3	PH ₃	HCN
NO ₂	O3 0	Combustibles (LEL)

AUTHORIZED GAS TESTING (AGT)



BW – GAS ALERT MICRO 5 -ATTACHMENTS






Figure 5. Attaching the Sample Probe

Insert the sample probe tubing into the confined space.

Depending upon the length of the tubing and the type of gas in the confined space, allow a minimum of 3 seconds per ft. of bose to ensure the readings stabilize before entering the area.

Item Description		
1	Motorized pump module	
2	Connector	
3	Sample probe	
4	Sample probe 10 in. tubing (custom lengths can be ordered)	
5	Flexible connector hose	

🛆 Warning

The sample probe must be used with the pump module only. Ensure that all connections are secure before sampling.




BW – GAS ALERT MICRO 5 - ACTIVATION



To activate the detector, press (1) in a normal atmosphere (20.9% oxygen).

Self-Test

Once the detector is activated, it performs several self-tests. Confirm the following tests occur.




If the battery has insufficient power to operate, the followi screen displays before deactivating.

Replace the batteries and reactivate the detector.

 All of the LCD elements display simultaneously as the detector beeps, flashes, vibrates, and briefly activates the backlight.







BW – GAS ALERT MICRO 5: SELF TEST



2. The version and serial number of the detector displays.

BW Micro5 105-000001 0A.D.F.TF

3. The date and time displays.

	Tuesday
0	ct 12-2004
	11:38pm
	Ō

The detector then runs a self-test to verify the sensors and power supply.



Self-test Successful: If successful, the following screen displays.






BW – GAS ALERT MICRO 5: SELF TEST




Self-test Unsuccessful: If a sensor fails the self-test, a warning displays indicating which sensor(s) has failed.




The TWA, STEL, low, and high alarm setpoints then display in the following order.












BW – GAS ALERT MICRO 5 – PUMP TEST

أدنــوك ADNOC

Pump Test (Optional)


8. If the pump module is attached to the detector, the following screens display.





When the following screen displays, block the pump inlet.

Pump	test:
block	inlet
8	* 🗅





BW – GAS ALERT MICRO 5 – PUMP TEST



If the pump inlet is not blocked within 10 seconds or the pump test fails, the following screens display.



If () is not pressed or the pump is not removed within 25 seconds, the detector performs the pump test again.



If the pump test is successful, the following screen displays and the self-test continues.

Pump test successful



BW – GAS ALERT MICRO 5 – O2 CALIBRATION




 Unless disabled in user options, the oxygen (O₂) sensor is calibrated automatically.

Automatic	:
02span	
<u>20.9</u>	
	D,

If the span is successful, the detector beeps twice.

Note

If the automatic O₂ calibration feature has been disabled, **Automatic O₂ span disabled** displays.







BW – GAS ALERT MICRO 5 – DUE DAYS FOR CALIBRATION



10. Lastly, the number of days remaining before calibration is due displays for all sensors.



If any sensor is past due for calibration, the name of the sensor and the number of days past due display.



Note

If any sensor is overdue, o displays continually until calibration is performed.



BW – GAS ALERT MICRO 5 – FORCED CALIBRATION



Force Calibration Is Enabled

If **Force cal** is enabled in the user options menu, calibration is mandatory before the detector enters normal operation.

Calibration	Press
mandatory	to start
before use	calibration

If \bigcirc is not pressed to s displays and the detect	tart calibration, the following or deactivates.	screen
	Calibration overdue. Turning off	



BW – GAS ALERT MICRO 5 – BUMP TEST



O2 and LEL bump test mandatory ₽ □

The mandatory daily bump test is applicable only to the LEL and O_2 sensors. The bump test must be performed otherwise the detector will deactivate.



Both the diffusion and pumped configurations are compatible with the MicroDock II - automatic bump test and calibration system



BW – GAS ALERT MICRO 5 – BUMP TEST PASSED




 When the following screen displays, apply the test gas. Ensure the cylinder icon is flashing before applying gas.



Note If the bump test is not performed, the detector deactivates.

Successful Bump Test: If the bump test passes, the following screens display.






BW – GAS ALERT MICRO 5 – BUMP TEST FAILED



Unsuccessful Bump Test: If the bump test is unsuccessful or the bump test is not performed, the following screen displays and the detector deactivates.






BW – GAS ALERT MICRO 5 – SELF TEST PASS/ FAIL



Self-Test Pass


If the detector passes the self-test, it enters normal operation displaying the ambient gas readings.



The detector begins recording the maximum gas exposure (MAX) and calculating the short-term exposure level (STEL) and time-weighted average (TWA) exposures.

Self -Test Fail

If a sensor fails, FAIL displays above that sensor on normal operating screen.





BW – GAS ALERT MICRO 5 – BATTERY TEST



Battery Test

The batteries are tested when the detector is activated and continuously thereafter. The battery power icon displays continually during normal operation. If battery power is low, flashes.





BW – GAS ALERT MICRO 5 – DETECTOR DEACTIVATION



Deactivating the Detector

To deactivate the detector, press and hold (1) while it beeps and flashes to the corresponding countdown.



At the end of the countdown the detector emits an extended beep and flash, and displays 0 before deactivating.

Note

If (1) is not held down for the complete countdown, the detector remains activated.



COMMON FAILURES



	PROBLEM	POSSIBLE CAUSE	SOLUTION
	The detector does not activate.	Depleted battery Damaged or defective detector	Charge battery. Refer to Charging the Battery. Sent for service/ repair
AUTHORIZED GAS TESTING (AGT)	The detector enters alarm immediately when activated.	Sensor needs to stabilize	Used sensor: wait 60 seconds New sensor: wait few minutes
	The detector enters alarm immediately when activated.	Low battery alarm	Charge battery.
	The detector enters alarm immediately when activated	Detector requires calibration	Calibrate the detector.
	The detector enters alarm immediately when activated	Hazardous environment	Leave the area immediately. Deactivate and reactivate in a safe area that is free of hazardous gas, in an atmosphere of 20.9% oxygen.



COMMON FAILURES



PROBLEM	POSSIBLE CAUSE	SOLUTION
The activation self-test fails.	General fault	Sent for service/ repair
The activation self-test fails.	Sensor failure	Replace the sensor. Refer to Replacing a Sensor or Sensor Filter.
Detector automatically deactivates during startup.	Battery power too low to operate	Charge battery.
Detector automatically deactivates during startup.	Force Calibration When Overdue option is enabled and calibration is not attempted	Calibrate the sensor(s) immediately.
Detector automatically deactivates during startup.	Force Bump When Overdue option is enabled and a bump test is not attempted	Bump test the sensor(s) immediately
Detector does not enter into alarm.	Alarm setpoint(s) defined incorrectly Alarm setpoint(s) set to zero	Reset alarm setpoints.
Detector does not respond to pushbutton.	Battery is depleted Detector is performing operations that do not require user input	Charge battery. Pushbutton operation restores automatically when the operation ends.

